

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

**LISTING No.** 7300-1209:231 Page 1 of 1

**CATEGORY:** Misc. Devices/Control Unit Accessories

**LISTEE:** System Sensor, 3825 Ohio Avenue, St. Charles IL 60174  
Contact: Trish Linhart (630) 377-6580 X1185 FAX (630) 377-7245

**DESIGN:** Models BEAMMK, BEAMSMK and BEAMLRK beam smoke detector mounting kits. Model BEAMLRK is for long range applications between 230 and 328 feet. Refer to listee's data sheet for detailed product description and operational considerations.

**RATING:** 15-32 VDC

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number, electrical rating, and UL label.

**APPROVAL:** Listed as projected beam smoke detector mounting kits for use with the following Projected Beam Smoke Detectors: Models BEAM1224, BEAM1224S, BEAM200, BEAM200S (CSFM Listing Nos. 7260-1209:228 & 229); FSB-200, FSB-200S (CSFM Listing No. 7260-0028:228); BEAM355, BEAM355S (CSFM Listing No. 7260-0075:209) and separately listed compatible fire alarm control units. Refer to listee's Installation Instruction Manual for details.

06-17-04



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JULY 22, 2004**

*Listing Expires **June 30, 2005***

Authorized By: **DIANE K. AREND, Senior Deputy  
Program Manager**